

Polo chimico ex Montedison Catellanza Olgiate Olona (VE)
Rapporto monitoraggio Agosto 2015 – Gennaio 2016

Data	PW1	PW2	PW3	PW4	PW5	PW6	PW7		
01/08/2015	1465253	1353782	1505420	1270057	1342787	1312833	1316121		
31/08/2015	1492942	1373432	1528040	1287640	1363634	1334653	1339563		
Ago Tot	27689	19650	22620	17583	20847	21820	23442	153651	m3
Q	38	27	31	24	29	30	33	213	m3/h
01/09/2015	1492942	1373432	1528040	1287640	1363634	1334653	1339563		
30/09/2015	1519794	1394076	1551293	1305980	1384650	1356620	1362553		
Set Tot	26852	20644	23253	18340	21016	21967	22990	155062	m3
Q	39	30	33	26	30	32	33	223	m3/h
01/10/2015	1519794	1394076	1551293	1305980	1384650	1356620	1362553		
31/10/2015	1544783	1415934	1575100	1324976	1406726	1381556	1385652		
Ott Tot	24989	21858	23807	18996	22076	24936	23099	159761	m3
Q	35	30	33	26	31	35	32	222	m3/h
01/11/2015	1544783	1415934	1575100	In manutenzione	1406726	1381556	1385652		
30/11/2015	1575505	1436477	1597739		1427703	1406852	1410165		
Nov Tot	30722	20543	22639	20977		25296	24513	144690	m3
Q	44	30	33	30		36	35	208	m3/h
01/12/2015	1575505	1436477	1597739	In manutenzione	1427703	1406852	1410165		
31/12/2015	1600862	1461356	1625377		1453016	1432314	1432756		
Dic Tot	25357	24879	27638	25313		25462	22591	151240	m3
Q	35	35	38	35		35	31	210	m3/h
01/01/2016	1600862	1461356	1625377	In manutenzione	1453016	1432314	1432756		
31/01/2016	1624518	1481833	1648097		1473564	1452945	1453569		
Gen Tot	23656	20477	22720	20548		20631	20813	128845	m3
Q	33	28	32	29		29	29	179	m3/h